LightLab INTERNATIONAL ALLENTOWN LLC


NVLAP TESTING Lab Code: 201079-0

# Report of Test

## LLIA003089-001

Indoor Distribution Photometry Test Report

Catalog Number: RH-140-60-D-B-M-4-515-R-H (Red Setting)
Pendant/highbay mounted, spun black aluminum outer housing, extruded aluminum heatsink and formed aluminum frame, frosted plastic enclosure below LEDs.
19 RGBW LED clusters with clear prismatic plastic optics below each.
One MeanWell XLG-200-24-A LED driver



Prepared For:
Aquarii
6805 Newbrook Avenue
East Syracuse, NY 13057, USA

| Performance Summary | | | | | |
|---|---|---|---|---|---|
| Input Voltage | 120.0 | Vac | Luminous Flux | 1086.7 | Lumens |
| Input Current | 0.3741 | A | Total Efficacy | 25.4 | Lm/W |
| Input Power | 42.72 | W | Downward Flux | 1086.7 | Lumens |
| Frequency | 60.00 | Hz | Downward Flux | 100.0 | % of Total |
| Power Factor | 0.952 | | | | |
| Current THD | 6.5 | % | | | |

This test report was issued by LightLab International Allentown, LLC without alterations or erasures.

Test date: 09/21/2026
Report date: 09/22/2026

Signed: Michael L. Grather Digitally signed by Michael L. Grather Date: 2026.09.22 16:27:35 -04'00'


*North America (issuing laboratory)*
LightLab International Allentown, LLC
905 Harrison Street, Suite 135
Allentown, PA 18103 USA
Ph: +1 484-273-0705
Fx: +1 484-209-5779
www.lightlaballentown.com



*Australasia & S.E. Asia*
LightLab International
50 Redcliffe Gardens Drive
Clontarf - Queensland, 4019, Australia
Ph : +61 7 3283 7862
Fx : +61 7 3283 8751
www.lightlabint.com

# Report of Test

## LLIA003089-001




Zonal Flux Summary

| Zone (Deg Vert) | Flux (Lumens) | Percent of Total | Zone (Deg Vert) | Flux (Lumens) | Percent of Total | Zone (Deg Vert) | Flux (Lumens) | Percent of Total |
|---|---|---|---|---|---|---|---|---|
| 0-10 | 145.7 | 13.4% | 90-100 | 0.0 | 0.0% | 0-20 | 444.2 | 40.9% |
| 10-20 | 298.5 | 27.5% | 100-110 | 0.0 | 0.0% | 0-30 | 694.3 | 63.9% |
| 20-30 | 250.1 | 23.0% | 110-120 | 0.0 | 0.0% | 0-40 | 846.9 | 77.9% |
| 30-40 | 152.6 | 14.0% | 120-130 | 0.0 | 0.0% | 0-60 | 1016 | 93.5% |
| 40-50 | 96.3 | 8.9% | 130-140 | 0.0 | 0.0% | 0-80 | 1086 | 100.0% |
| 50-60 | 73.2 | 6.7% | 140-150 | 0.0 | 0.0% | 10-90 | 941.0 | 86.6% |
| 60-70 | 53.7 | 4.9% | 150-160 | 0.0 | 0.0% | 20-50 | 499.0 | 45.9% |
| 70-80 | 16.1 | 1.5% | 160-170 | 0.0 | 0.0% | 40-90 | 239.8 | 22.1% |
| 80-90 | 0.5 | 0.0% | 170-180 | 0.0 | 0.0% | 60-90 | 70.3 | 6.5% |
| 0-90 | 1087 | 100.0% | 90-180 | 0.0 | 0.0% | 0-180 | 1087 | 100.0% |

# Report of Test

## LLIA003089-001

Luminous Intensity (Candela) Table

| Vertical (Gamma) Angles - Data was acquired in 0.5° increments, 2.5° increments shown. | Lateral (C-Plane) Angles | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 22.5 | 45 | 67.5 | 90 | 112.5 | 135 | 157.5 | 180 |
| | 0 | 1687 | 1687 | 1687 | 1687 | 1687 | 1687 | 1687 | 1687 | 1687 |
| | 2.5 | 1664 | 1664 | 1664 | 1664 | 1664 | 1664 | 1664 | 1664 | 1664 |
| | 5 | 1601 | 1601 | 1601 | 1601 | 1601 | 1601 | 1601 | 1601 | 1601 |
| | 7.5 | 1503 | 1503 | 1503 | 1503 | 1503 | 1503 | 1503 | 1503 | 1503 |
| | 10 | 1379 | 1379 | 1379 | 1379 | 1379 | 1379 | 1379 | 1379 | 1379 |
| | 12.5 | 1236 | 1236 | 1236 | 1236 | 1236 | 1236 | 1236 | 1236 | 1236 |
| | 15 | 1086 | 1086 | 1086 | 1086 | 1086 | 1086 | 1086 | 1086 | 1086 |
| | 17.5 | 935 | 935 | 935 | 935 | 935 | 935 | 935 | 935 | 935 |
| | 20 | 791 | 791 | 791 | 791 | 791 | 791 | 791 | 791 | 791 |
| | 22.5 | 659 | 659 | 659 | 659 | 659 | 659 | 659 | 659 | 659 |
| | 25 | 543 | 543 | 543 | 543 | 543 | 543 | 543 | 543 | 543 |
| | 27.5 | 443 | 443 | 443 | 443 | 443 | 443 | 443 | 443 | 443 |
| | 30 | 360 | 360 | 360 | 360 | 360 | 360 | 360 | 360 | 360 |
| | 32.5 | 292 | 292 | 292 | 292 | 292 | 292 | 292 | 292 | 292 |
| | 35 | 239 | 239 | 239 | 239 | 239 | 239 | 239 | 239 | 239 |
| | 37.5 | 197 | 197 | 197 | 197 | 197 | 197 | 197 | 197 | 197 |
| | 40 | 165 | 165 | 165 | 165 | 165 | 165 | 165 | 165 | 165 |
| | 42.5 | 141 | 141 | 141 | 141 | 141 | 141 | 141 | 141 | 141 |
| | 45 | 122 | 122 | 122 | 122 | 122 | 122 | 122 | 122 | 122 |
| | 47.5 | 108 | 108 | 108 | 108 | 108 | 108 | 108 | 108 | 108 |
| | 50 | 97 | 97 | 97 | 97 | 97 | 97 | 97 | 97 | 97 |
| | 52.5 | 88 | 88 | 88 | 88 | 88 | 88 | 88 | 88 | 88 |
| | 55 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 |
| | 57.5 | 75 | 75 | 75 | 75 | 75 | 75 | 75 | 75 | 75 |
| | 60 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 69 |
| | 62.5 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 | 62 |
| | 65 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 |
| | 67.5 | 47 | 47 | 47 | 47 | 47 | 47 | 47 | 47 | 47 |
| | 70 | 37 | 37 | 37 | 37 | 37 | 37 | 37 | 37 | 37 |
| | 72.5 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 | 26 |
| | 75 | 14 | 14 | 14 | 14 | 14 | 14 | 14 | 14 | 14 |
| | 77.5 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 |
| | 80 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| | 82.5 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| | 85 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | 87.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | 90 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

16 lateral half-planes of data were acquired, 22.5 degree increments shown.

# Report of Test

## LLIA003089-001

Luminous Intensity (Candela) Table

| Vertical (Gamma) Angles - Data was acquired in 0.5° increments, 2.5° increments shown. | Lateral (C-Plane) Angles | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|
| | 0 | 22.5 | 45 | 67.5 | 90 | 112.5 | 135 | 157.5 | 180 |
| 90 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 92.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 95 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 97.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 100 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 102.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 105 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 107.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 110 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 112.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 115 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 117.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 120 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 122.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 127.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 130 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 132.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 135 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 137.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 140 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 142.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 145 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 147.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 150 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 152.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 155 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 157.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 160 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 162.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 165 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 167.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 170 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 172.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 175 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 177.5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 180 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

16 lateral half-planes of data were acquired, 22.5 degree increments shown.

*North America (issuing laboratory)*
LightLab International Allentown, LLC
905 Harrison Street, Suite 135
Allentown, PA 18103 USA
Ph: +1 484-273-0705
Fx: +1 484-209-5779
www.lightlaballentown.com



*Australasia & S.E. Asia*
LightLab International
50 Redcliffe Gardens Drive
Clontarf - Queensland, 4019, Australia
Ph : +61 7 3283 7862
Fx : +61 7 3283 8751
www.lightlabint.com

LightLab INTERNATIONAL ALLENTOWN LLC

NVLAP TESTING Lab Code: 201079-0

# Report of Test

## LLIA003089-001

### Coefficients of Utilization/Room Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance 0.20

| RC | 80 | | | | | 70 | | | | | 50 | | | | 30 | | | | 10 | | | 0 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| RW | 70 | 50 | 30 | 10 | | 70 | 50 | 30 | 10 | | 50 | 30 | 10 | | 50 | 30 | 10 | | 50 | 30 | 10 | 0 |
| RCR | | | | | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | | 116 | 116 | 116 | 116 | | 111 | 111 | 111 | | 106 | 106 | 106 | | 102 | 102 | 102 | 100 |
| 1 | 113 | 109 | 107 | 104 | | 110 | 107 | 105 | 102 | | 103 | 101 | 99 | | 99 | 98 | 96 | | 96 | 95 | 93 | 92 |
| 2 | 106 | 100 | 96 | 92 | | 104 | 99 | 95 | 91 | | 95 | 92 | 89 | | 92 | 90 | 87 | | 90 | 87 | 85 | 83 |
| 3 | 100 | 93 | 87 | 83 | | 98 | 91 | 86 | 82 | | 89 | 84 | 81 | | 86 | 82 | 79 | | 84 | 81 | 78 | 76 |
| 4 | 94 | 86 | 80 | 75 | | 92 | 85 | 79 | 75 | | 83 | 78 | 74 | | 80 | 76 | 73 | | 79 | 75 | 72 | 70 |
| 5 | 89 | 80 | 74 | 69 | | 88 | 79 | 73 | 69 | | 77 | 72 | 68 | | 76 | 71 | 67 | | 74 | 70 | 67 | 65 |
| 6 | 85 | 75 | 68 | 64 | | 83 | 74 | 68 | 64 | | 73 | 67 | 63 | | 71 | 66 | 63 | | 70 | 66 | 62 | 61 |
| 7 | 80 | 70 | 64 | 59 | | 79 | 70 | 64 | 59 | | 68 | 63 | 59 | | 67 | 62 | 59 | | 66 | 62 | 58 | 57 |
| 8 | 77 | 66 | 60 | 56 | | 75 | 66 | 60 | 56 | | 65 | 59 | 55 | | 64 | 59 | 55 | | 63 | 58 | 55 | 53 |
| 9 | 73 | 63 | 57 | 52 | | 72 | 62 | 56 | 52 | | 61 | 56 | 52 | | 60 | 56 | 52 | | 60 | 55 | 52 | 50 |
| 10 | 70 | 60 | 54 | 50 | | 69 | 59 | 53 | 50 | | 58 | 53 | 49 | | 58 | 53 | 49 | | 57 | 52 | 49 | 48 |

For absolute test reports, RUs are expressed as a percentage of total lumen output. For relative test reports, CUs are expressed as a percentage of total lamp output. Calculations were based on published IES procedures, and are based on the zonal cavity method. Basic assumptions: 1) Room surfaces are lambertian reflectors. 2) Incident flux on each surface is uniformly distributed. 3) The room is spectrally neutral. When luminaires are not evenly distributed throughout the room, or do not exhibit lateral symmetry, CU values may differ from actual performance.

### Circle of Light Plot

| Height(ft) | Illuminance at Nadir (fc) | Ground-level distance to half-of-nadir illuminance (ft) 0-180 deg | 90-270 deg |
|---|---|---|---|
| 6.0 | 46.9 | 3.67 | 3.67 |
| 8.0 | 26.4 | 4.89 | 4.89 |
| 10.0 | 16.9 | 6.12 | 6.12 |
| 12.0 | 11.7 | 7.34 | 7.34 |
| 14.0 | 8.6 | 8.56 | 8.56 |
| 16.0 | 6.6 | 9.79 | 9.79 |

### Spacing Criterion

SC: 0.6

### Average Luminance (cd/m$^2$)

| | 0 deg Plane | 45 deg Plane | 90 deg Plane |
|---|---|---|---|
| 0 | 36889 | 36889 | 36889 |
| 45 | 3784 | 3784 | 3784 |
| 55 | 3097 | 3097 | 3097 |
| 65 | 2840 | 2840 | 2840 |
| 75 | 1183 | 1183 | 1183 |
| 85 | 116 | 116 | 116 |

### Beam and Field Angle

0-180 Degree Plane

Beam Angle: 38.1°

Field Angle: 79.4°

90-270 Degree Plane

Beam Angle: 38.1°

Field Angle: 79.4°

# Report of Test

## LLIA003089-001

UGR Table - Corrected


| Reflectances | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Ceiling Cavity | | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 |
| Walls | | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 |
| Floor Cavity | | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 |
| Room Size | | UGR Viewed Crosswise | | | | | UGR Viewed Endwise | | | | |
| X=2H | Y=2H | 12.7 | 13.9 | 13.1 | 14.2 | 14.5 | 12.7 | 13.9 | 13.1 | 14.2 | 14.5 |
| | 3H | 14.2 | 15.3 | 14.6 | 15.6 | 16.0 | 14.2 | 15.3 | 14.6 | 15.6 | 16.0 |
| | 4H | 14.4 | 15.4 | 14.8 | 15.8 | 16.2 | 14.4 | 15.4 | 14.8 | 15.8 | 16.2 |
| | 6H | 14.3 | 15.3 | 14.7 | 15.6 | 16.0 | 14.3 | 15.3 | 14.7 | 15.6 | 16.0 |
| | 8H | 14.3 | 15.2 | 14.7 | 15.5 | 16.0 | 14.3 | 15.2 | 14.7 | 15.5 | 16.0 |
| | 12H | 14.3 | 15.1 | 14.7 | 15.5 | 15.9 | 14.3 | 15.1 | 14.7 | 15.5 | 15.9 |
| 4H | 2H | 13.3 | 14.2 | 13.7 | 14.6 | 15.0 | 13.3 | 14.2 | 13.7 | 14.6 | 15.0 |
| | 3H | 14.9 | 15.7 | 15.3 | 16.1 | 16.5 | 14.9 | 15.7 | 15.3 | 16.1 | 16.5 |
| | 4H | 15.1 | 15.8 | 15.5 | 16.2 | 16.7 | 15.1 | 15.8 | 15.5 | 16.2 | 16.7 |
| | 6H | 15.0 | 15.6 | 15.4 | 16.1 | 16.5 | 15.0 | 15.6 | 15.4 | 16.1 | 16.5 |
| | 8H | 14.9 | 15.5 | 15.4 | 16.0 | 16.4 | 14.9 | 15.5 | 15.4 | 16.0 | 16.4 |
| | 12H | 14.9 | 15.4 | 15.4 | 15.9 | 16.4 | 14.9 | 15.4 | 15.4 | 15.9 | 16.4 |
| 8H | 4H | 15.1 | 15.6 | 15.5 | 16.1 | 16.6 | 15.1 | 15.6 | 15.5 | 16.1 | 16.6 |
| | 6H | 15.0 | 15.4 | 15.5 | 15.9 | 16.4 | 15.0 | 15.4 | 15.5 | 15.9 | 16.4 |
| | 8H | 14.9 | 15.3 | 15.4 | 15.8 | 16.3 | 14.9 | 15.3 | 15.4 | 15.8 | 16.3 |
| | 12H | 14.9 | 15.2 | 15.4 | 15.7 | 16.3 | 14.9 | 15.2 | 15.4 | 15.7 | 16.3 |
| 12H | 4H | 15.0 | 15.5 | 15.5 | 16.0 | 16.5 | 15.0 | 15.5 | 15.5 | 16.0 | 16.5 |
| | 6H | 14.9 | 15.3 | 15.4 | 15.8 | 16.3 | 14.9 | 15.3 | 15.4 | 15.8 | 16.3 |
| | 8H | 14.9 | 15.2 | 15.4 | 15.7 | 16.3 | 14.9 | 15.2 | 15.4 | 15.7 | 16.3 |

Maximum UGR = 16.7

# Report of Test

## LLIA003089-001

## Iso-Illuminance Plot





The isofootcandle values shown in the plot above are based on a mounting height of h = 8.0 feet. Grid values show multiples of mounting height. The isoilluminance contour lines are expressed in units of footcandles. The values expressed are based on the direct light from a single unit without the contribution of room reflections.

# Report of Test

## LLIA003089-001

## Additional Pictures of Test Subject





# Report of Test

## LLIA003089-001

| | |
|---|---|
| Test Distance | 9.5 m |
| Ambient Temperature | 25.1 °C |

Notes

The laboratory has not participated in the selection of samples to be tested. All testing is performed on the understanding that the significance of the report is limited to the extent that the test sample is representative of production units.

Tested in accordance with the applicable sections of IES LM-79-24. Format of reports and angular increments based on IES LM-41-20 and LM-46-20.

The luminous intensity values, and other derived quantities, contained in this report are based on the absolute data, as measured.

Prorating the performance of the sample for the use of other component combinations (such as lamp / LED / Ballast / driver), or for use in different environmental conditions than that tested, may produce erroneous results.

This report is free of erasures and corrections.

Photometric intensity values are reported using the CIE C-Gamma coordinate system as defined in CIE publication number 121.

This report may contain data that are not covered by the NVLAP accreditation. Quantities marked with ‡ are not covered.

This report must not be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST, or any agency of the Federal Government.