LightLab INTERNATIONAL ALLENTOWN LLC

NVLAP TESTING Lab Code: 201079-0

Report of Test

LLIA003089-019

Indoor Distribution Photometry Test Report

Catalog Number: VN-75-R-34-D-B-M-4-515-R-H (White Setting)
Pendant/highbay mounted, spun black aluminum outer housing, extruded aluminum heatsink and formed aluminum frame, no enclosure.
7 RGBW LED clusters with clear prismatic plastic optics below each.
One MeanWell EPP-150-12 LED driver



Prepared For:
Aquarii
6805 Newbrook Avenue
East Syracuse, NY 13057, USA

Performance Summary					
Input Voltage	120.0	Vac	Luminous Flux	1019.3	Lumens
Input Current	0.1837	A	Total Efficacy	50.6	Lm/W
Input Power	20.14	W	Downward Flux	1019.3	Lumens
Frequency	60.00	Hz	Downward Flux	100.0	% of Total
Power Factor	0.914				
Current THD	13.4	%			

This test report was issued by LightLab International Allentown, LLC without alterations or erasures.

Test date: 09/21/2026
Report date: 09/23/2026


Signed: Michael L. Grather Digitally signed by Michael L. Grather Date: 2026.09.23 14:54:28 -04'00'

North America (issuing laboratory)
LightLab International Allentown, LLC
905 Harrison Street, Suite 135
Allentown, PA 18103 USA
Ph: +1 484-273-0705
Fx: +1 484-209-5779
www.lightlaballentown.com

Australasia & S.E. Asia
LightLab International
50 Redcliffe Gardens Drive
Clontarf - Queensland, 4019, Australia
Ph : +61 7 3283 7862
Fx : +61 7 3283 8751
www.lightlabint.com

Report of Test

LLIA003089-019



Zonal Flux Summary

Zone (Deg Vert)	Flux (Lumens)	Percent of Total	Zone (Deg Vert)	Flux (Lumens)	Percent of Total	Zone (Deg Vert)	Flux (Lumens)	Percent of Total
0-10	334.8	32.8%	90-100	0.0	0.0%	0-20	769.4	75.5%
10-20	434.6	42.6%	100-110	0.0	0.0%	0-30	926.3	90.9%
20-30	156.8	15.4%	110-120	0.0	0.0%	0-40	975.6	95.7%
30-40	49.4	4.8%	120-130	0.0	0.0%	0-60	1014	99.5%
40-50	25.8	2.5%	130-140	0.0	0.0%	0-80	1019	100.0%
50-60	13.0	1.3%	140-150	0.0	0.0%	10-90	684.5	67.2%
60-70	4.5	0.4%	150-160	0.0	0.0%	20-50	232.0	22.8%
70-80	0.4	0.0%	160-170	0.0	0.0%	40-90	43.7	4.3%
80-90	0.1	0.0%	170-180	0.0	0.0%	60-90	4.9	0.5%
0-90	1019	100.0%	90-180	0.0	0.0%	0-180	1019	100.0%

Report of Test

LLIA003089-019

Luminous Intensity (Candela) Table

Vertical (Gamma) Angles - Data was acquired in 0.5° increments, 2.5° increments shown.	Lateral (C-Plane) Angles									
	0	22.5	45	67.5	90	112.5	135	157.5	180
0	4363	4363	4363	4363	4363	4363	4363	4363	4363
2.5	4217	4217	4217	4217	4217	4217	4217	4217	4217
5	3880	3880	3880	3880	3880	3880	3880	3880	3880
7.5	3388	3388	3388	3388	3388	3388	3388	3388	3388
10	2781	2781	2781	2781	2781	2781	2781	2781	2781
12.5	2152	2152	2152	2152	2152	2152	2152	2152	2152
15	1584	1584	1584	1584	1584	1584	1584	1584	1584
17.5	1109	1109	1109	1109	1109	1109	1109	1109	1109
20	747	747	747	747	747	747	747	747	747
22.5	489	489	489	489	489	489	489	489	489
25	314	314	314	314	314	314	314	314	314
27.5	204	204	204	204	204	204	204	204	204
30	138	138	138	138	138	138	138	138	138
32.5	98	98	98	98	98	98	98	98	98
35	74	74	74	74	74	74	74	74	74
37.5	59	59	59	59	59	59	59	59	59
40	49	49	49	49	49	49	49	49	49
42.5	40	40	40	40	40	40	40	40	40
45	33	33	33	33	33	33	33	33	33
47.5	27	27	27	27	27	27	27	27	27
50	22	22	22	22	22	22	22	22	22
52.5	18	18	18	18	18	18	18	18	18
55	14	14	14	14	14	14	14	14	14
57.5	12	12	12	12	12	12	12	12	12
60	9	9	9	9	9	9	9	9	9
62.5	6	6	6	6	6	6	6	6	6
65	4	4	4	4	4	4	4	4	4
67.5	3	3	3	3	3	3	3	3	3
70	2	2	2	2	2	2	2	2	2
72.5	1	1	1	1	1	1	1	1	1
75	0	0	0	0	0	0	0	0	0
77.5	0	0	0	0	0	0	0	0	0
80	0	0	0	0	0	0	0	0	0
82.5	0	0	0	0	0	0	0	0	0
85	0	0	0	0	0	0	0	0	0
87.5	0	0	0	0	0	0	0	0	0
90	0	0	0	0	0	0	0	0	0

16 lateral half-planes of data were acquired, 22.5 degree increments shown.

Report of Test

LLIA003089-019

Luminous Intensity (Candela) Table

Vertical (Gamma) Angles - Data was acquired in 0.5° increments, 2.5° increments shown.	Lateral (C-Plane) Angles								
	0	22.5	45	67.5	90	112.5	135	157.5	180
90	0	0	0	0	0	0	0	0	0
92.5	0	0	0	0	0	0	0	0	0
95	0	0	0	0	0	0	0	0	0
97.5	0	0	0	0	0	0	0	0	0
100	0	0	0	0	0	0	0	0	0
102.5	0	0	0	0	0	0	0	0	0
105	0	0	0	0	0	0	0	0	0
107.5	0	0	0	0	0	0	0	0	0
110	0	0	0	0	0	0	0	0	0
112.5	0	0	0	0	0	0	0	0	0
115	0	0	0	0	0	0	0	0	0
117.5	0	0	0	0	0	0	0	0	0
120	0	0	0	0	0	0	0	0	0
122.5	0	0	0	0	0	0	0	0	0
125	0	0	0	0	0	0	0	0	0
127.5	0	0	0	0	0	0	0	0	0
130	0	0	0	0	0	0	0	0	0
132.5	0	0	0	0	0	0	0	0	0
135	0	0	0	0	0	0	0	0	0
137.5	0	0	0	0	0	0	0	0	0
140	0	0	0	0	0	0	0	0	0
142.5	0	0	0	0	0	0	0	0	0
145	0	0	0	0	0	0	0	0	0
147.5	0	0	0	0	0	0	0	0	0
150	0	0	0	0	0	0	0	0	0
152.5	0	0	0	0	0	0	0	0	0
155	0	0	0	0	0	0	0	0	0
157.5	0	0	0	0	0	0	0	0	0
160	0	0	0	0	0	0	0	0	0
162.5	0	0	0	0	0	0	0	0	0
165	0	0	0	0	0	0	0	0	0
167.5	0	0	0	0	0	0	0	0	0
170	0	0	0	0	0	0	0	0	0
172.5	0	0	0	0	0	0	0	0	0
175	0	0	0	0	0	0	0	0	0
177.5	0	0	0	0	0	0	0	0	0
180	0	0	0	0	0	0	0	0	0

16 lateral half-planes of data were acquired, 22.5 degree increments shown.

LightLab INTERNATIONAL ALLENTOWN LLC

NVLAP TESTING Lab Code: 201079-0

Report of Test

LLIA003089-019

Coefficients of Utilization/Room Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance 0.20

RC	80					70					50				30				10			0
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10	0
RCR																						
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102	100
1	115	113	111	109		112	110	109	107		106	105	104		103	102	101		99	99	98	96
2	111	107	104	101		109	105	102	100		102	100	98		99	97	96		97	95	94	92
3	107	102	98	95		105	101	97	94		98	95	93		96	93	91		94	92	90	89
4	103	98	93	90		102	96	93	90		94	91	89		93	90	88		91	89	87	85
5	100	94	89	86		98	93	89	86		91	88	85		90	87	84		88	86	84	82
6	97	90	86	83		95	89	85	82		88	84	82		87	84	81		86	83	81	80
7	94	87	83	79		93	86	82	79		85	82	79		84	81	78		83	80	78	77
8	91	84	80	77		90	84	79	77		83	79	76		82	78	76		81	78	76	75
9	88	81	77	74		88	81	77	74		80	76	74		79	76	74		79	76	73	72
10	86	79	75	72		85	79	75	72		78	74	72		77	74	72		77	74	71	70

For absolute test reports, RUs are expressed as a percentage of total lumen output. For relative test reports, CUs are expressed as a percentage of total lamp output. Calculations were based on published IES procedures, and are based on the zonal cavity method. Basic assumptions: 1) Room surfaces are lambertian reflectors. 2) Incident flux on each surface is uniformly distributed. 3) The room is spectrally neutral. When luminaires are not evenly distributed throughout the room, or do not exhibit lateral symmetry, CU values may differ from actual performance.

Circle of Light Plot

Height(ft)	Illuminance at Nadir (fc)	Ground-level distance to half-of-nadir illuminance (ft) 0-180 deg	90-270 deg
6.0	121.2	2.51	2.51
8.0	68.2	3.34	3.34
10.0	43.6	4.18	4.18
12.0	30.3	5.01	5.01
14.0	22.3	5.85	5.85
16.0	17.0	6.68	6.68

Spacing Criterion

SC: 0.4

Average Luminance (cd/m^2)

	0 deg Plane	45 deg Plane	90 deg Plane
0	203820	203820	203820
45	2163	2163	2163
55	1170	1170	1170
65	465	465	465
75	25	25	25
85	19	19	19

Beam and Field Angle

0-180 Degree Plane

Beam Angle: 24.8°

Field Angle: 46.3°

90-270 Degree Plane

Beam Angle: 24.8°

Field Angle: 46.3°

Report of Test

LLIA003089-019

UGR Table - Corrected


Reflectances											
Ceiling Cavity		70	70	50	50	30	70	70	50	50	30
Walls		50	30	50	30	30	50	30	50	30	30
Floor Cavity		20	20	20	20	20	20	20	20	20	20
Room Size		UGR Viewed Crosswise					UGR Viewed Endwise				
X=2H	Y=2H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	3H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	4H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	6H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	8H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	12H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
4H	2H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	3H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	4H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	6H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	8H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	12H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
8H	4H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	6H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	8H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	12H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
12H	4H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	6H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10
	8H	<10	<10	<10	<10	<10	<10	<10	<10	<10	<10

Maximum UGR = <10

Report of Test

LLIA003089-019

Iso-Illuminance Plot




The isofootcandle values shown in the plot above are based on a mounting height of h = 8.0 feet. Grid values show multiples of mounting height. The isoilluminance contour lines are expressed in units of footcandles. The values expressed are based on the direct light from a single unit without the contribution of room reflections.

Report of Test

LLIA003089-019

Additional Pictures of Test Subject





Report of Test

LLIA003089-019

Test Distance	9.5 m
Ambient Temperature	25.1 °C

Notes

The laboratory has not participated in the selection of samples to be tested. All testing is performed on the understanding that the significance of the report is limited to the extent that the test sample is representative of production units.

Tested in accordance with the applicable sections of IES LM-79-24. Format of reports and angular increments based on IES LM-41-20 and LM-46-20.

The luminous intensity values, and other derived quantities, contained in this report are based on the absolute data, as measured.

Prorating the performance of the sample for the use of other component combinations (such as lamp / LED / Ballast / driver), or for use in different environmental conditions than that tested, may produce erroneous results.

This report is free of erasures and corrections.

Photometric intensity values are reported using the CIE C-Gamma coordinate system as defined in CIE publication number 121.

This report may contain data that are not covered by the NVLAP accreditation. Quantities marked with ‡ are not covered.

This report must not be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST, or any agency of the Federal Government.